

REGARDING SAFE DRINKING WATER AND SANITARY CONDITION

CERTIFICATE

No. 304

Date : 19-1-2026

It is certified that an inspection team headed by Trilok Singh (Quality Manager) from Omega Test House inspected the RYAN EDUNATION SCHOOL , Dadu Dayal Nagar, Near Water-Tank Extended Mansarovar Jaipur and found that the Ryan Education School has safe drinking water facilities for the students and members of staff of the institution and is maintaining the hygienic sanitation condition in the school building & the campus as per the norms prescribed by the Central/State/U.T Govt.

The above valid for a period of one Year

Report Enclosed.

Signature with Seal: 

Name : Tilok Singh

Designation : Quality Manager



To

RYAN EDUNATION SCHOOL

Dadu Dayal Nagar, Near Water Tank,
Extended Mansarovar Jaipur-302029



OMEGA TEST HOUSE PVT. LTD.

An ISO Certified, FSSAI, MoEF & NABL Accredited Laboratory

Lab: J-889, Sitapura Industrial Area, Jaipur (Raj)-302022

Head Office: 2/60, Malviya Nagar, Jaipur (Raj)-302017

Contact: 09414074020, 09829051363, 0141-2521969, Email: omegatesthouse@gmail.com



NABL SCOPE

Format No.: OTHPL/QC/RF/25

TC-15122

TEST REPORT

Sample Name	Tap Water (Ground Floor)	Sample Code	26010517
Report No.	OTHPL/RN-202600517	Report Issue date	19/01/2026
ULR No.	TC15122260000496F	Page No.	01 OF 01
Reference to Sampling	QCOI 008	Sample Collected By	Lab representative

Customer Name & Address:		Sample Receiving Date:	15/01/2026
Ryan Education School, Muhanan Mandi Road, ISKON Road, Ext. Mansarovar, Jaipur.		Date of Testing	16/01/2026
		Date of Completion	19/01/2026
		Sample Qty. & Condition	1 Ltr. & Ok
Environmental Conditions Under which test performed	Room Temperature	Registration No.	RAJ.1713/012971

Appearance: - Clear Colorless Liquid.

CHEMICAL ANALYSIS

S. No.	Parameters	Results	Units	Test Method	Limits IS : 10500/2012 Desirable Limit/ Rejection Limit
1.	Odor	Agreeable	NA	IS : 3025 (P-5)	Agreeable
2.	Turbidity	Nil	NTU	IS : 3025 (P-10)	1 Max./5 Max
3.	pH	7.98	NA	IS : 3025 (P-11)	6.5 to 8.5
4.	Total Dissolved Solids	490	mg/l.	IS : 3025 (P-16)	500 Max. / 2000 Max.
5.	Total Hardness as CaCO ₃	136.12	mg/l.	IS : 3025 (P-21)	200 Max./ 600 Max.
6.	Calcium Hardness as Ca	32.05	mg/l.	IS : 3025 (P-40)	75 Max./ 200 Max.
7.	Magnesium Hardness as Mg	13.60	mg/l.	IS : 3025 (P-46)	30 Max./100 Max.
8.	Chloride as Cl	61.25	mg/l.	IS : 3025 (P-32)	250 Max./ 1000 Max.
9.	Alkalinity to (P) as CaCO ₃	Nil	mg/l.	IS : 3025 (P-23)	-----
10.	Alkalinity to (M) as CaCO ₃	385.92	mg/l.	IS : 3025 (P-23)	200 Max./ 600 Max.
11.	Nitrate as NO ₃	57.15	mg/l.	IS : 3025 (P-34)	45 Max./No relaxation
12.	Sulphate as SO ₄	26.18	mg/l.	IS : 3025 (P-24)	200 Max./ 400 Max.
13.	Iron as Fe	BDL(<0.01)	mg/l.	IS : 3025 (P-53)	0.3 Max./ No relaxation
14.	Fluoride as F	0.78	mg/l.	IS : 3025 (P-60)	1.0 Max./ 1.5 Max.
15.	Sodium as Na	196.80	mg/l.	IS : 3025 (P-45)	150 Max

MICROBIOLOGICAL ANALYSIS

1.	E.coli/ 100 ml	Absent/100 ml	Present or Absent/100 ml	IS : 15185-2016	Shall not be detectable In any 100 ml of sample
2.	Coliform/ 100 ml	Absent/100 ml	Present or Absent/100 ml	IS : 15185-2016	Shall not be detectable In any 100 ml of sample

Note: - 1.BDL- Below Detection Limit, NA- Not Applicable

2. The results relate only to items tested.

3. The information about the sample provided by customer.

END OF REPORT



Note:

- (1.) The result listed refer only to the tested samples and applicable parameters. Endorsement of product is neither inferred nor implied
- (2.) Total Liability of our concern is limited to the invoiced amount.
- (3.) The report is not to be reproduced wholly or in part and cannot be used as an evidence in the court of law and should not be used in any advertising media without our special permission in writing



OMEGA TEST HOUSE PVT. LTD.

An ISO Certified, FSSAI, MoEF & NABL Accredited Laboratory

Lab: J-889, Sitapura Industrial Area, Jaipur (Raj)-302022

Head Office: 2/60, Malviya Nagar, Jaipur (Raj)-302017

Contact: 09414074020, 09829051363, 0141-2521969, Email: omegatesthouse@gmail.com



NABL SCOPE

TC-15122

Format No:-OTHPL/QC/RF/25

TEST REPORT

Sample Name	RO Water (Ground Floor)	Sample Code	26010518
Report No.	OTHPL/RN-202600518	Report Issue date	19/01/2026
ULR No.	TC15122260000497F	Page No.	01 OF 01
Reference to Sampling	QCOI 008	Sample Collected By	Lab representative

Customer Name & Address:		Sample Receiving Date:	15/01/2026
Ryan Education School, Muhana Mandi Road, ISKON Road, Ext. Mansarovar, Jaipur.		Date of Testing	16/01/2026
		Date of Completion	19/01/2026
		Sample Qty. & Condition	1 Ltr. & Ok
Environmental Conditions Under which test performed	Room Temperature	Registration No.	RAJ.1713/012971

Appearance: - Clear Colorless Liquid.

CHEMICAL ANALYSIS

S. No.	Parameters	Results	Units	Test Method	Limits IS : 10500/2012 Desirable Limit/ Rejection Limit
1.	Odor	Agreeable	NA	IS : 3025 (P-5)	Agreeable
2.	Turbidity	Nil	NTU	IS : 3025 (P-10)	1 Max./5 Max
3.	pH	7.28	NA	IS : 3025 (P-11)	6.5 to 8.5
4.	Total Dissolved Solids	75	mg/l.	IS : 3025 (P-16)	500 Max. / 2000 Max.
5.	Total Hardness as CaCO ₃	24.02	mg/l.	IS : 3025 (P-21)	200 Max./ 600 Max.
6.	Calcium Hardness as Ca	4.80	mg/l.	IS : 3025 (P-40)	75 Max./ 200 Max.
7.	Magnesium Hardness as Mg	2.91	mg/l.	IS : 3025 (P-46)	30 Max./100 Max.
8.	Chloride as Cl	11.48	mg/l.	IS : 3025 (P-32)	250 Max./ 1000 Max.
9.	Alkalinity to (P) as CaCO ₃	Nil	mg/l.	IS : 3025 (P-23)	-----
10.	Alkalinity to (M) as CaCO ₃	40.12	mg/l.	IS : 3025 (P-23)	200 Max./ 600 Max.
11.	Nitrate as NO ₃	7.41	mg/l.	IS : 3025 (P-34)	45 Max./No relaxation
12.	Sulphate as SO ₄	4.25	mg/l.	IS : 3025 (P-24)	200 Max./ 400 Max.
13.	Iron as Fe	BDL(<0.01)	mg/l.	IS : 3025 (P-53)	0.3 Max./ No relaxation
14.	Fluoride as F	0.21	mg/l.	IS : 3025 (P-60)	1.0 Max./ 1.5 Max.
15.	Sodium as Na	23.83	mg/l.	IS : 3025 (P-45)	150 Max

MICROBIOLOGICAL ANALYSIS

1.	<i>E.coli.</i> / 100 ml	Absent/100 ml	Present or Absent/100 ml	IS : 15185-2016	Shall not be detectable In any 100 ml of sample
2.	Coliform/ 100 ml	Absent/100 ml	Present or Absent/100 ml	IS : 15185-2016	Shall not be detectable In any 100 ml of sample

Note: - 1.BDL- Below Detection Limit, NA- Not Applicable

2. The above parameters are analyzed as per IS: 3025 & Complies the IS 10500:2012.

3. The results relate only to items tested.

4. The information about the sample provided by customer.

END OF REPORT

(Microbiologist)
Authorized Signatory

Quality Manager
Authorized Signatory

Note:

(1.) The result listed refer only to the tested samples and applicable parameters. Endorsement of product is neither inferred nor implied

(2.) Total Liability of our concern is limited to the invoiced amount.

(3.) The report is not to be reproduced wholly or in part and cannot be used as an evidence in the court of law and should not be used in any advertising media without our special permission in writing